



DEPARTMENTAL SUBMISSION

DEPARTMENT: Public Works - City Engineering

FILE NUMBER: Public Works - City Engineering-0498

*** RE:**

Submitting reso. autho. Petition No. x2025-035 – Henry Ford Health System, request for encroachment within the northerly part of Lincoln St., 60 ft. wide, adjacent to the parcel commonly known as 6405 Lincoln St., for the installation of six privately own

*** SUMMARY:**

Henry Ford Health System, request for encroachment within the northerly part of Lincoln St., 60 ft. wide, adjacent to the parcel commonly known as 6405 Lincoln St., for the installation of six privately owned steel service pipes: three insulated chilled water pipes with a 36-inch outside diameter and three insulated hot water pipes with a 30-inch outside diameter, with 1-foot spacing between each pipe. The system utilizes steel service pipes with polyurethane insulation and HDPE jacket. The proposed below grade encroachment is for the Henry Ford Health Central Energy Hub (CEH) hydronic piping

*** RECOMMENDATION:**

Approve

*** DEPARTMENTAL CONTACT:**

Name: Raven Wright

Position: Supervisor of Maps & Records

***=REQUIRED**